



# Rocketship Legacy Prep PCS - Lead in Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Rocketship Legacy Prep PCS	WS-091-001	Food Prep Sink	1	In kitchen first clockwise from entry door	-	Left	WF-012018-091001-01	4/19/18	FT-FY18-012018-091001	<1	<1
Rocketship Legacy Prep PCS	WS-091-002	Food Prep Sink	1	In kitchen second clockwise from entry door	-	Right	WF-012018-091002-01	4/19/18	FT-FY18-012018-091002	<1	<1
Rocketship Legacy Prep PCS	WS-091-003	Food Prep Sink	1	In Pre-K cafeteria	-	-	WF-012018-091003-01	4/19/18	FT-FY18-012018-091003	2.2	<1
Rocketship Legacy Prep PCS	WS-091-004	Health Suite	1	In health suite room 118	-	-	WF-012018-091004-01	4/19/18	FT-FY18-012018-091004	<1	<1
Rocketship Legacy Prep PCS	WS-091-005	Classroom Faucet	1	In classroom 100	-	-	WF-012018-091005-01	4/19/18	FT-FY18-012018-091005	2.9	<1
Rocketship Legacy Prep PCS	WS-091-006	Classroom Faucet	1	In classroom 101	-	-	WF-012018-091006-01	4/19/18	FT-FY18-012018-091006	1.4	<1
Rocketship Legacy Prep PCS	WS-091-007	Classroom Faucet	1	In classroom 102	-	-	WF-012018-091007-01	4/19/18	FT-FY18-012018-091007	2.3	<1
Rocketship Legacy Prep PCS	WS-091-008	Classroom Faucet	1	In classroom 103	-	-	WF-012018-091008-01	4/19/18	FT-FY18-012018-091008	1.1	<1
Rocketship Legacy Prep PCS	WS-091-009	Classroom Faucet	1	In classroom 104	-	-	WF-012018-091009-01	4/19/18	FT-FY18-012018-091009	2.3	<1
Rocketship Legacy Prep PCS	WS-091-010	Classroom Faucet	1	In classroom 105	-	-	WF-012018-091010-01	4/19/18	FT-FY18-012018-091010	3.1	<1
Rocketship Legacy Prep PCS	WS-091-011	Classroom Faucet	1	In classroom 106	-	-	WF-012018-091011-01	4/19/18	FT-FY18-012018-091011	2.0	<1
Rocketship Legacy Prep PCS	WS-091-012	Classroom Faucet	1	In classroom 107	-	-	WF-012018-091012-01	4/19/18	FT-FY18-012018-091012	3.9	<1
Rocketship Legacy Prep PCS	WS-091-013	Break Room	1	In teachers' workroom 131	-	-	WF-012018-091013-01	4/19/18	FT-FY18-012018-091013	3.5	<1
Rocketship Legacy Prep PCS	WS-091-014	Cooler	1	In hallway adjacent to elevators	High	Left	WF-012018-091014-01	4/19/18	FT-FY18-012018-091014	<1	<1
Rocketship Legacy Prep PCS	WS-091-015	Cooler	1	In hallway adjacent to elevators	Low	Right	WF-012018-091015-01	4/19/18	FT-FY18-012018-091015	<1	<1
Rocketship Legacy Prep PCS	WS-091-016	Cooler	1	In hallway adjacent to room 120	High	Left	WF-012018-091016-01	4/19/18	FT-FY18-012018-091016	<1	<1
Rocketship Legacy Prep PCS	WS-091-017	Cooler	1	In hallway adjacent to room 120	Low	Right	WF-012018-091017-01	4/19/18	FT-FY18-012018-091017	<1	<1
Rocketship Legacy Prep PCS	WS-091-018	Cooler	1	In hallway adjacent to room 132	High	Left	WF-012018-091018-01	4/19/18	FT-FY18-012018-091018	<1	<1
Rocketship Legacy Prep PCS	WS-091-019	Cooler	1	In hallway adjacent to room 132	Low	Right	WF-012018-091019-01	4/19/18	FT-FY18-012018-091019	<1	<1
Rocketship Legacy Prep PCS	WS-091-020	Cooler	2	In hallway adjacent to elevators	High	Left	WF-012018-091020-01	4/19/18	FT-FY18-012018-091020	<1	<1
Rocketship Legacy Prep PCS	WS-091-021	Cooler	2	In hallway adjacent to elevators	Low	Right	WF-012018-091021-01	4/19/18	FT-FY18-012018-091021	<1	<1
Rocketship Legacy Prep PCS	WS-091-022	Cooler	2	In hallway adjacent to room 208	High	Left	WF-012018-091022-01	4/19/18	FT-FY18-012018-091022	<1	<1
Rocketship Legacy Prep PCS	WS-091-023	Cooler	2	In hallway across from room 208	Low	Right	WF-012018-091023-01	4/19/18	FT-FY18-012018-091023	<1	<1



# Community College Prep (Wheeler Road) - Lead in Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Rocketship Legacy Prep PCS	WS-091-024	Cooler	2	In hallway across from room 215	High	Left	WF-012018-091024-01	4/19/18	FT-FY18-012018-091024	<1	<1
Rocketship Legacy Prep PCS	WS-091-025	Cooler	2	In hallway across from room 215	Low	Right	WF-012018-091025-01	4/19/18	FT-FY18-012018-091025	<1	<1